

# FIRE SAFETY AUDIT REPORT (2023-24)

AT

**KJ's Educational Institute**  
TRINITY INTERNATIONAL SCHOOL  
Sr. 25 & 27, KONDHWA SASWAD ROAD,  
BOPDEO GHAT, PUNE 411048

By

**SAMRUDHI ENGINEERS**




SURVEY NO.25, OPP KUMAR PALMS, NEAR SOMJI BUS STOP,  
SOMJI, KONDWA BK, PUNE 411048

**MAHARASHTRA FIRE LICENSE NO.**

**MFS / LA / RF-169 / RD-162**

On

**21<sup>ST</sup> AUG 2023**

Audit undertaken by	Reviewed and Approved by
	 
Project Manager Samrudhi Engineers	Madhukar Chede Maharashtra Fire License No. MFS / LA / RF-169 / RD-162

  
**PRINCIPAL**  
Trinity International School



  
**Manager**  
Trinity International School


**ABOUT KJ's Educational Institute TRINITY INTERNATIONAL  
SCHOOL:**

Kalyan Jadhav Educational Institute (KJEI) the East Cost mecca of Engineering, Management & Science The institute Within Pune is spread across 110 acres of picturesque campus nestled in the green valley, with its near zero pollution and fresh air, creates a perfectly conducive low-stress climate for learning, research, innovation and character-building. With over 8000 students, KJEI has a strong sense of community born of its small size the goes hand-in-hand with an atmosphere that is charged with youthful vibrancy, experience and maturity

**AUDIT CONDUCTED AT:**

<b>Name</b>	:	KJ's Educational Institute TRINITY INTERNATIONAL SCHOOL
<b>Location</b>	:	Kondhwa- Saswad Road
<b>Operation Manager</b>	:	Prasad Konde
<b>Total Area</b>	:	9665.73 Sq. Ft.
<b>Employee Strength</b>	:	100 Nos
<b>Fire Safety Audit Performed On</b>	:	21 <sup>st</sup> Aug 2023



Audit undertaken by	Reviewed and Approved by
	
Project Manager Samrudhi Engineers	Madhukar Chede Maharashtra Fire License No. MFS / LA / RF-169 / RD-162

  
**PRINCIPAL**  
**Trinity International School**  
**Manager**  
**Trinity International School**

### Fire-fighting Equipment

SR. NO.	EQUIPMENT	QUANTITY
1.	Main Pump 50 HP	01 Nos
2.	Jockey Pump 5.5 HP	01 Nos
3.	Single Hydrant Valve	09 Nos
4.	Hose Box with Canvas Pipe and Nozzle	09 Nos
5.	ABC 4 KG	12 Nos
6.	CO2 4.5 KG	01 Nos
7.	Manual Call Point	03 Nos
8.	Hooter	03 Nos
9.	Alarm Panel	01 Nos

The above said fire protection equipment installed in good working conditions

Audit undertaken by	Reviewed and Approved by
	
Project Manager Samrudhi Engineers	Madhukar Chede Maharashtra Fire License No. MFS / LA / RF-169 / RD-162

