

PRIMARY HEALTH CENTER, FURSUNGI
TAL-HAVELI DIST-PUNE


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 128
18/3/2023

Date. 18/3/2023

It is certified that an inspection team headed by DR. ARVIND KOKATE (Name of officers with Designation) from HEALTH DEPARTMENT (Name of Department/Office) inspected the Trinity International School located at Survey No.25&27, Bopdeo Ghat, Kondhwa- Saswad Road, Pune-411 048 on 17/3/2023 and found that the Trinity International School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of one (1) Year.

Signature with Seal: 

Name: DR. ARVIND SHANKAR KOKATE

Designation: Medical Officer G.H.U.


To,
Trinity International School
Survey No.25&27, Bopdeo Ghat,
Kondhwa- Saswad Road, Pune-411 048



MEDICAL OFFICER
P.H.C Fursungi
Tal Haveli, Dist.Pune


PRINCIPAL
Trinity International School


Manager
Trinity International School



'IMRAT', Lane No. B/23, Raikarnagar, Opp Mor Bunglow, Dhayarigaon,
Pune - 411041. Maharashtra (India) Tel.: 020-24392871 Mob.: +91 9422009576

Format No.: IPL/Form/17

Water Sample Analysis Report

REPORT NO.	IPL / T / 03 / 41078		DATE OF ISSUE	17 / 03 / 2023	
Name and Address	K. J. EDUCATIONAL INSTITUTES TRINITY INTERNATIONAL SCHOOL Sr. No.25 & 27, Pisoli, Near BopdevGhat,Kondhwa, Tal. - Haveli, Dist. - Pune, Pin. - 411048.			Order Reference: -	
Sample Description / Type	DRINKING WATER SAMPLE	Sample Collected by	Party		
Sampling Location	--	Sample Quantity / Packing	1 lit.		
Date of Sampling	--	Date of Sample Receipt	14 / 03 / 2023		
Sampling Procedure	--				
Date of Start of Analysis	14 / 03 / 2023		Date of Completion of Analysis	17 / 03 / 2023	
SR. NO.	PARAMETER	UNIT	RESULT	LIMITS AS PER IS 10500:2012 [Max]	METHODS OF ANALYSIS
A	ORGANOLEPTIC & PHYSICAL PARAMETERS				
1	Colour	Hazen	<2	5	IS: 3025 (Part 4) – 1983
2	Odour	--	Agreeable	Agreeable	APHA 22 nd Edition, Part 2150B, Page 2-16
3	pH	--	7.30	6.5 to 8.5	APHA 22 nd Edition, Part 4500-H* B, Page 4-92
4	Taste	--	Agreeable	Agreeable	APHA 22 nd Edition, Part 2160B, Page 2-20
5	Turbidity	NTU	<1	1	APHA 22 nd Edition, Part 2130B, Page 2-13
6	TDS	mg/lit	75.2	500	APHA 22 nd Edition, Part 2540C, Page 2-65
7	Calcium [as Ca]	mg/lit	10.42	75	APHA 22 nd Edition, Part 3500-Ca B, Page 3-67
8	Chlorides [as Cl]	mg/lit	8.16	250	APHA 22 nd Edition, Part 4500-Cl B, Page 4-75
9	Fluoride	mg/lit	<0.2	1.0	APHA 22 nd Edition, Part 4500-F D, Page 4-87
10	Residual Free Chlorine	mg/lit	0.21	0.2 [MIN]	APHA 22 nd Edition, Part 4500-Cl B, Page 4-60
11	Iron [as Fe]	mg/lit	<0.075	0.3	APHA 22 nd Edition, Part 3110, Page 3-14, 3500 Fe B 3-77
12	Magnesium [as Mg]	mg/lit	6.64	30	APHA 22 nd Edition, Part 3500, Page 3-84
13	Nitrate	mg/lit	<1	45	APHA 22 nd Edition, Part 4500-NO ₃ B, Page 4-122
14	Sulphates [as SO ₄]	mg/lit	<1	200	APHA 22 nd Edition, Part 4500 SO ₄ ²⁻ E, Page 4-190
15	Total Alkalinity as CaCO ₃	mg/lit	30	200	APHA 22 nd Edition, Part 2320 B, Page 2-34
16	Total Hardness as CaCO ₃	mg/lit	53.7	200	APHA 22 nd Edition, Part 2340 C, Page 2-44
B	BACTERIOLOGICAL PARAMETERS				
17	E – Coli	/100ml	Absent	Absent	IS: 1622 – 1981
18	Total Coliform Bacteria/MPN	MPN/100ml	Absent	Absent	IS: 1622 – 1981

Remarks/Observations: - Test results complies as per IS:10500 (Drinking water) for above parameters. Water is Potable.

Authorised Signatory
(Mr. Sanjeev Katariya, Managing Director)

End of Test Report
Page 1

Results related to sample (s) drawn from client only.
This certificate shall not be reproduced except in full without the written permission of authorized signatory INSTA POLLUTECH LABS,PUNE.

Environment Laboratory Recognized By MoEF, GOVERNMENT OF INDIA, NEW DELHI
UNDER E.P. ACT 1986, VIDE GR NO. 2850 (E) SR. NO. 102

E-mail: sanjeevkatariya@instapollutechlabs.com, instapollutech@gmail.com

Visit us at : www.instapollutechlabs.com

IG/IPL/MoEF/JAN2019/

PRINCIPAL

Trinity International School

Manager

Trinity International School